




Bellcore GR-63-CORE Earthquake Zone 4 Report for
the Cannon Cabinet
Series 2000-SUK

For

Cannon Technologies Ltd.
1155 Squires Beach Road
Pickering, Ontario Canada L1W 3T9
February 5, 2002

Revision 1.0

Project Handler:



Michelle Henderson
Associate Project Engineer
NEBS Services
Conformity Assessment Services

Reviewed By:



Arnold C. Sheldon
Engineering Team Leader
NEBS Services
Conformity Assessment Services

This Document was prepared by:

Underwriters Laboratories, Inc.
12 Laboratory Drive
Research Triangle Park, NC 27709
(919) 549-1400

Copyright © 2002 Underwriters Laboratories, Inc.

All Rights Reserved

Underwriters Laboratories Inc. reports apply only to the specific samples tested under stated test conditions. It is the manufacturer's responsibility to assure that additional production units of this model are manufactured with identical electrical and mechanical components. Underwriters Laboratories Inc. shall have no liability for any deductions, inferences, or generalizations drawn by the client or others from Underwriters Laboratories Inc. issued reports.

This report is the confidential property of the client. As a mutual protection to our clients, the public, and ourselves, extracts from the test report shall not be reproduced except in full without UL's written approval. This report shall not be used, by the client, to claim product endorsement by NVLAP or any agency of the US government.



Report of Measurements for the Cannon Cabinet Series 2000-SUK Table of Contents

1.0 EXECUTIVE SUMMARY	4
1.1 INTRODUCTION.....	4
1.2 REVISION HISTORY.....	4
1.3 TEST RESULT SUMMARY.....	4
2.0 ANALYSIS SCOPE	6
2.1 PRODUCT DESCRIPTION.....	6
2.2 MODIFICATIONS NECESSARY FOR COMPLIANCE.....	6
2.3 EUT CONFIGURATION.....	6
2.4 EUT OPERATION.....	6
2.5 NEBS TESTING FACILITIES.....	6
3.0 PROJECT TEAM	7
3.1 UL TECHNICAL STAFF.....	7
3.2 CANNON TECHNICAL STAFF.....	7
ANNEX 1 - EQUIPMENT PHOTOS	8
ANNEX 2 - PRODUCT CONFIGURATION	11
ANNEX 3 - EARTHQUAKE DATA	16



1.0 EXECUTIVE SUMMARY

1.1 Introduction

This audit report examines the Cannon Cabinet Series 2000-SUK (Part Number: CAB-458080000105NA) for conformance to Bellcore's Zone 4 Earthquake requirements of GR-63-CORE, Issue 1, October 1995. Table 1.3 is a detailed summary of the results of this testing.

1.2 Revision History

Revision Number	Description	Revision performed by
1.0	None, original	N/A

1.3 Test Result Summary

The table below summarizes the test results of the Cannon Cabinet Series 2000-SUK. The product was compared to the seismic environmental compatibility generic criteria. The details of this test are located in the appropriate Annex for the section under investigation.

Note: The information in the table below should not be used without understanding the underlying circumstances of the test results that are presented in the Annexes of this report.



TABLE 1.3 GR-63-CORE TEST RESULTS SUMMARY

Physical Compatibility GR-63-CORE:				
Test	NEBS Reference	Meets Criteria (Y/N/NA)	Test Data Annex	UL's Comments
<ul style="list-style-type: none"> Earthquake Vibration 				
<ul style="list-style-type: none"> Earthquake – Physical performance 	R4-44	Y	3	See enclosed results.
	R4-45	Y	3	See enclosed results.
	R4-46	Y	3	See enclosed results.
	O4-47	Y	3	See enclosed results.
<ul style="list-style-type: none"> Earthquake – Functional performance 	R4-48	NA	-	The test was conducted on a non-operational system.
	O4-49	NA	-	The test was conducted on a non-operational system.



2.0 ANALYSIS SCOPE

2.1 Product Description

The Cannon Cabinet Series 2000-SUK consists of a heavy steel welded frame with hinged, locking front and rear doors. Side panels are inset and screw mounted. The top is a removable perforated panel.

Refer to Annex 2 for detailed drawings of the EUT provided by Cannon. It should be noted that the cabinet tested did not incorporate the slotted mounting holes shown in sheet 3 of the enclosed drawings. Mounting holes were drilled by engineers of UL.

2.2 Modifications Necessary for Compliance

The following modifications were incorporated into the EUT in order to fully comply with the requirements of the specification: None.

2.3 EUT Configuration

The Cabinet was configured by engineers of UL in accordance with specifications provided by Cannon. A diagram illustrating the configuration of the weights in the frame is shown in Annex 2.

2.4 EUT Operation

This testing was conducted on a non-operational unit.

2.5 NEBS Testing Facilities

Test Category	NRTL / ISO 9000	Location
Physical Protection:		
• Earthquake	Y	UL; RTP, NC



3.0 Project Team

3.1 UL Technical Staff

The following personnel supervised and/or performed technical aspects of GR-63-CORE.

Michelle Henderson (919) 549-1471
Associate Project Engineer

3.2 Cannon Technical Staff

The following personnel were present throughout this investigation to configure and insure proper assembly of the system under test and to assist UL engineers with the test procedure:

None

4.0 Analysis Criteria

The product was evaluated to the Earthquake Zone 4 requirements contained in the following document:

- GR-63-CORE, Issue 1, October 1995, Network Equipment – Building System (NEBS) Requirements: Physical Protection



ANNEX 1 - Equipment Photos

Figure 1: Test Set-Up for Side to Side Axis




Figure 2: Test Set-Up Front to Back Axis





Figure 3: Test Set-Up Vertical Axis




ANNEX 2 - Product Configuration

Front of Cabinet



Back of Cabinet



Note: Forty pounds of weight was mounted to the top of the frame in order to simulate overhead cable weight.



COPYRIGHT IN THIS DRAWING BELONGS TO CANNON TECHNOLOGIES Inc. IT MUST NOT BE COPIED OR DISCLOSED TO THIRD PARTIES WITHOUT WRITTEN PERMISSION FROM CANNON TECHNOLOGIES Inc.

IF IN DOUBT ASK

PERFORATED REMOVABLE TOP PANEL

INSET PERFORATED FRONT DOOR

FRONT RH ISO SCALE 0.085

INSET PERFORATED REAR DOOR

REAR RH ISO SCALE 0.085

HEAVY STEEL WELDED FRAME

PARTS LIST			
ITEM	PART/MODEL	DESCRIPTION	QTY
1	047C00001045	TRAY, CABLE, METAL, 100mm, 45U	2
2	098C44800101NA	DOOR, PERF, WELDED, 800x44U	2
3	184C00051101NA	ASM, COVER, CUTOFF, RECEPTACLE	1
4	202C45050002NA	PANEL, BOX, INFILL, HEAVY, 50mm, 45U	2
5	202C45050003NA	PANEL, INFILL, HEAVY, 50mm, 45U	2
6	296C01000045NA	POST, MOUNTING, HEAVY, 45U	2
7	314C00808001NA	ROOF, VENTED, SPECIAL, 800x800	1
8	394C01008001NA	MEMBER, SUPPORT, SINGLE, SPECIAL, 800	1
9	505B45808001NA	ASM, CABINET, WELDED, 45Ux800x800	1
10	DIN 6797A M3	WASHER, EXT. TOOTH, STL, ZN, M3	2
11	DIN 7500 M (965) M3x8	SCR, TAPTITE, POZI, CSK, STL, ZN, M3x8	2
12	EAD191	BUTTON, SNAP, ESD	2
13	LA0006	LABEL, ESD	2
14	PANDUIT CI. 5LG6	COVER, DUCT, 1-1/2"	2
15	PANDUIT GI. 5X4LG6	DUCT, WIRING, 1-1/2"x4"	2

PARTS LIST (HARDWARE, NOT MODELED)			
ITEM	PART/MODEL	DESCRIPTION	QTY
H1	CA021	CAGE NUT TOOL	1
H2	FMN08206P	M6 S/PROOF FLANGED HEX NUT	24
H3	FMS0070612P	M6x12 POZI PAN HEAD SCREW	24
H4	KP0004	FRONT PANEL FIXINGS (50 OFF)	1
H5	KP0007	CABINET JOINING KIT	1
H6	KP0015	700-800 WIDE CABINET HARDWARE KIT	1
H7	KP0201	CABINET EARTH BONDING KIT	1


NOTES


- ASSEMBLE COMPONENTS AS SHOWN
- EQUIPMENT MOUNTING RAILS ARE ZINC PLATED


---	5	REVISE FRAME, ROOF & DOORS, ADD BUS BAR, SUPPORT MEMBER & MISC HDWR	11-Nov-01
---	4	REVISED WELDED FRAME, REPLACED SIDE PANEL W/ STD	03-Oct-00
---	3	UPDATED PARTS LIST, WAS ASM CAB-45808000103NA	22-Sep-00
---	2	WELDED FRAME & ROOF	28-Aug-00
---	1	INITIAL RELEASE	12-Aug-00

CANNON TECHNOLOGIES Inc.	PROJECTION	TITLE	PART NUMBER: CAB-45808000105NA	ECN	DRG ISSUE	DESCRIPTION	DATE
PICKERING, ONTARIO, CANADA TEL 905-426-2869 FAX 905-426-2893	TOLERANCES UNLESS OTHERWISE STATED: HOLE DIAMETER AS: 1 OVER 1 METRE AS: 1		ASM, CABINET, 45Ux800x800				
SET BACK XX INS BEND RAD XX ALL DIMENSIONS IN MM (INCHES)	MATERIAL	FINISH	FIRST USED ON.	CHECKED	DRAWN	DRAWING No.	PRODUCT GROUP
	SEE PARTS LIST	SEE COMPONENTS	SYCAMORE		D.G.	CAB-45808000105NA	ISSUE 5 SHT 1 OF 4









ANNEX 3 – Earthquake Data

4.4.1.1 Earthquake Environment Criteria

(R4-44, [110]) – (O4-49, [115])

Test Instruments

Instrument Number	Manufacturer	Model	Range Used	Cal. Date	Cal. Due
AX0022	Data Physics	Vector	mV/G	05/07/01	05/31/02
AX0016	Dytran	3166A1	mV/G	01/08/00	01/08/03
AX0014	Dytran	3166A1	mV/G	01/08/00	01/08/03
AX0018	Dytran	3166A1	mV/G	01/08/00	01/08/03
AX0021	Dytran	3166A1	mV/G	01/08/00	01/08/03
WD0057	Chatillon	DWT 5000	5000 lb	02/23/01	02/28/02
MG1126	Senix	Ultra U	mV/inch	10/04/01	10/31/02
MG1127	Senix	Ultra U	mV/inch	10/04/01	10/31/02
Q15455-1	Microtech	SXS-FB	lbs	04/23/01	04/30/02
Q15455-2	Microtech	SXS-FB	lbs	04/23/01	04/30/02
Q15455-3	Microtech	SXS-FB	lbs	04/23/01	04/30/02
Q15455-4	Microtech	SXS-FB	lbs	04/23/01	04/30/02

Results

Sensor Description and Location

Channel	Sensor Type	Location
1	Accelerometer	Table
2	Accelerometer	Top of frame
3	Accelerometer	Middle of frame

Weight at top of framework: 40 lbs.

Weight of loaded frame: 1392 lbs.

- Mounting hardware was provided by the manufacturer.
 Mounting hardware was not provided by the manufacturer.

Describe mounting hardware: ½ x 13NC x 2-¼" lg strain bolts, 2 small round washers, 1 large round washer (1-cm thick)



4.4.1.1 Earthquake Environment Criteria (Continued)
(R4-44, [110]) – (O4-49, [115])

Results-Continued

X-AXIS (Front to Back)

Maximum displacement at top of framework: 0.67 inches

Resonant Frequency: Top 11.323 Hz Middle 11.323 Hz

- The resonant frequency was greater than 2 Hz.
- The resonant frequency was not greater than 2 Hz.

- The resonant frequency was greater than 6 Hz.
- The resonant frequency was not greater than 6 Hz.

- The EUT did continue to function as intended during and at the completion of testing.
- The EUT did not continue to function as intended during and at the completion of testing.
- NA – Test conducted on a non-operational unit.

If not, please describe errors _____

- The EUT did sustain any change in physical condition.
- The EUT did not sustain any change in physical condition.


If so, please describe change _____

Strain Bolt Data:

<u>Bolt</u>	<u>Initial Bolt Load (lbs)</u>	<u>Peak Bolt Load (lbs)</u>
1	6853	7211
2	6679	6690
3	5547	6151
4	8010	8012



02LB041 Cannon Front to Back



4.4.1.1 Earthquake Environment Criteria (Continued)
(R4-44, [110]) – (O4-49, [115])

Results-Continued

Y-AXIS (Side to Side)

Maximum displacement at top of framework: 1.23 inches

Resonant Frequency: Top 13.931 Hz Middle 13.931 Hz

- The resonant frequency was greater than 2 Hz.
- The resonant frequency was not greater than 2 Hz.

- The resonant frequency was greater than 6 Hz.
- The resonant frequency was not greater than 6 Hz.

- The EUT did continue to function as intended during and at the completion of testing.
- The EUT did not continue to function as intended during and at the completion of testing.
- NA – Test conducted on a non-operational unit.

If not, please describe errors _____

- The EUT did sustain any change in physical condition.
- The EUT did not sustain any change in physical condition.


If so, please describe change _____

Strain Bolt Data:

<u>Bolt</u>	<u>Initial Bolt Load (lbs)</u>	<u>Peak Bolt Load (lbs)</u>
1	8410	8460
2	8870	9020
3	8300	9810
4	8450	9030



02LB041 Cannon Side to Side



4.4.1.1 Earthquake Environment Criteria (Continued)
(R4-44, [110]) – (O4-49, [115])

Results-Continued

Z-AXIS (Vertical)

- The EUT did continue to function as intended during and at the completion of testing.
- The EUT did not continue to function as intended during and at the completion of testing.
- NA – Test conducted on a non-operational unit.



If not, please describe errors _____

- The EUT did sustain any change in physical condition.
- The EUT did not sustain any change in physical condition.



If so, please describe change _____







Front to Back Sine Survey




Front To Back Seismic Plots










Side to Side Sine Survey
Top of Frame







Middle of Frame



Side to Side Seismic Plots







Vertical Seismic Plots

